Rotary actuator for butterfly valves

- Nominal torque 400 Nm
- Nominal voltage AC 230 V
- · Control Open-close, 3-point
- · with 2 integrated auxiliary switches



Technical data Electrical data AC 230 V Nominal voltage 50/60 Hz Nominal voltage frequency AC 207...253 V Nominal voltage range Power consumption in operation 221 W Power consumption in operation note incl. heating Power consumption for wire sizing 253 VA Current consumption 1.1 A Auxiliary switch 2 x SPDT, 1 x 3° / 1 x 87° Switching capacity auxiliary switch 1 mA...5 (3 inductive) A, DC 5 V ... AC 250 V Connection supply / control Terminals 2.5 mm² (Wire 2 x 1.5 mm² or 1 x 2.5 mm²) Parallel operation No **Functional data** Torque motor 400 Nm Manual override temporary with handwheel (non-rotating) Angle of rotation Angle of rotation note Internal limit switch, not adjustable Running time motor 21 s Duty cycle 30 % (= active time 21 s / operating time 70 s) Sound power level motor 70 dB(A) Position indication Mechanically (integrated) Safety Protection class IEC/EN I Protective earth Protection class auxiliary switch IEC/EN I Protective earth Degree of protection IEC/EN IP67 EMC CE according to 2014/30/EU CE according to 2014/35/EU Low voltage directive Mode of operation Type 1 Control pollution degree 4 -30...65°C Ambient temperature Non-operating temperature -30...80°C Ambient humidity 95% r.h., non-condensing Maintenance Maintenance-free Mechanical data Connection flange F10

Safety notes



Weight

Materials

Weight

Housing material

 This device has been designed for use in stationary heating, ventilation and air conditioning systems and must not be used outside the specified field of application, especially in aircraft or in any other airborne means of transport.

22 kg

Aluminium pressure casting

- · Caution: Power supply voltage!
- Only authorised specialists may carry out installation. All applicable legal or institutional installation regulations must be complied during installation.
- The device does not contain any parts that can be replaced or repaired by the user.
- The device contains electrical and electronic components and must not be disposed
 of as household refuse. All locally valid regulations and requirements must be
 observed.

Rotary actuator for butterfly valves, Open-close, 3-point, AC 230 V, 400 Nm



Product features

Simple direct mounting Simple direct mounting on the butterfly valve. The mounting orientation in relation to

the butterfly valve can be selected in 90° (angle) increments.

Manual override The butterfly valve can be closed (turn clockwise) and opened (turn anticlockwise)

with the handwheel. The handwheel does not move while the motor is running. The

butterfly valve remains in its position as long as no voltage is applied.

Internal heating An internal heater prevents condensation buildup.

High functional reliability Mechanical end stops limit the actuator to −2° and 92°. The internal limit switches

interrupt the voltage supply to the motor. In addition, a motor thermostat provides overload protection and interrupts the voltage supply if the actuator is used outside of

the specified temperatures.

Combination valve/actuator Refer to the valve documentation for suitable valves, their permitted medium

temperatures and closing pressures.

Signalling The integrated auxiliary switches are equipped with a gold/silver coating that permits

integration both in circuits with low currents (mA range) and in ones with larger-sized currents (A range) in accordance with the specifications in the data sheet. It should be noted with this application however that the contacts can no longer be used in the milliampere range after larger currents have been applied to them, even if this has

taken place only once.

Electrical installation




Notes

· Caution: Power supply voltage!

Wiring diagrams

AC 230 V, open-close, 3-point



H: Internal heating (no need to connect internal heating for indoor applications with constant temperature conditions)

LS3: Auxiliary switch 100% (butterfly

valve open)

LS4: Auxiliary switch 0% (butterfly

valve closed)



Settings



Notes


• Limit switches TC1/TC2 and angle of rotation limitation are provided with sealing varnish and may not be adjusted.

Setting cam

The setting cams for limit and auxiliary switches can be accessed by removing the housing cover.

Optionally, auxiliary switches LS4 / LS3 can be connected for signalling. Limit switches LS2 / LS1 interrupt the voltage to the motor and are controlled by setting cams TC...

The setting cams turn with the stem. The butterfly valve closes when the stem is turning clockwise (cw) and opens when the stem is turning counterclockwise (ccw).




TC1/TC2 with sealing varnish: limit switches are secured against adjustment

Settings of setting cams TC..

- TC4 for auxiliary switch position closed (factory setting 3°).
- TC3 for auxiliary switch position open (factory setting 87°).
- TC2 for limit switch closed (0°).
- TC1 for limit switch open (90°).

Adjusting setting cams

- 1) Use a 2.5 mm Allen key to unscrew the corresponding setting cams TC..
- 2) Turn the setting cam using the Allen key
- 3) Set as shown in the illustration below
- 4) Use the Allen key to tighten the corresponding setting cams




TC1: OPEN TC2: CLOSED TC3: Present position TC4: Desired position

Mechanical angle of rotation limitation

The mechanical angle of rotation (3) is set at the factory to -2° and 92° and cannot be changed.


The handwheel is rotated by means of a worm gear in a planetary gear unit. The gearing is stopped mechanically by means of two setscrews (3).



3: Angle of rotation limitation with sealing varnish:

Must not be adjusted
4: Connection handwheel

Relationship between mechanical angle of rotation limitation, limit and auxiliary switches




1: Auxiliary switch adjustable TC3 / TC4
 2: Limit switch fix adjusted TC1 / TC2
 3: Mechanical angle of rotation fix adjusted



Dimensions [mm]

Dimensional drawings



Further documentation

- Data sheets for butterfly valvesInstallation instructions for actual Installation instructions for actuators and/or butterfly valves
- Notes for project planning for butterfly valves